


RevN	Revision Note	Date	Signature
0	INITIAL RELEASE	3/10/04	AVD

**** IMPORTANT ****
INSURE ELECTRICAL POWER IS OFF TO ELECTRICAL BOX BEFORE PROCEEDING!
MINIMUM 90* EC SUPPLY CONDUCTORS



INSTALLATION STEPS:

- ** IMPORTANT **** INSURE ELECTRICAL SERVICE IS TURNED OFF BEFORE PROCEEDING
1. REMOVE ALL ITEMS FROM BOX. INSPECT FOR DAMAGE AND REPORT DAMAGED ITEM TO STONE MATHER DESIGNS.
 2. FASTEN MOUNTING CROSS BAR TO OUTLET BOX.
 3. CONNECT WHITE WIRES WITH WHITE SUPPLY WIRE AND CONNECT BLACK WIRES WITH BLACK SUPPLY WIRE USING WIRE NUTS.
 4. LOOP BARE COPPER GROUNDING WIRE AROUND GROUND SCREW ON CROSS BAR AND TIGHTEN. CONNECT GROUNDING WIRE FROM OUTLET BOX WITH BARE COPPER GROUNDING WIRE FROM FIXTURE USING WIRE NUT.
 5. PLACE A BEAD OF SILICONE SEALANT AROUND CANOPY EDGE (FOR EXTERIOR MOUNTING ONLY)
 6. PLACE FIXTURE OVER NIPPLE AND SECURE WITH CAP NUT, TIGHTEN TO SECURE TO WALL OR CEILING.

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED AND OR A QUALIFIED ELECTRICIAN.

UNDERWRITERS LABORATORIES COMPLIANCE

UL

1. INCANDESCENT FILE #E170691
 2. FLUORESCENT FILE #E172522

STONE MATHER DESIGNS

4444 Tower Rd. SW
 Albuquerque, NM 87121
 Phone (505) 247-4276
 Fax (505) 247-4538

INSTALLATION INSTRUCTIONS

SPOT LIGHT CYLINDER
 DSP, DWSP

Date	3/11/2014	Designed by	AVD	Sheet	1/1
------	-----------	-------------	-----	-------	-----

A
B
C
D
E
F
G
H

A
B
C
D
E
F
G
H